

Reply of DMRC in response to Queries/Clarifications raised by prospective participants of the in respect of Tender for Running Contract for Installation of Signages at Metro Stations upto 31st march 2017 –OP-2016-03

Sr.No.	Description of Query / Clarification Sought by the Participant	DMRC's Reply / Clarification
1.	Query against Tender Fee and EMD Exemption - Please confirm that Tender Fees and EMD will be exempted for small scale industries registered under NSIC and MSME as already allowed according to your website www.tenderwizard.com .	Tender Fee and EMD Exemption is not applicable in this tender.
2.	Clarification on Maintenance term - In tender document Maintenance is required mentioned so please elaborate the scope and period of maintenance work.	Scope of Maintenance is about replacement of installed signages with the new is applicable till the validity of Tender Performance Security i.e. beyond six months of contract period. Period of Maintenance is upto validity of tender performance Security i.e. beyond six months of contract period.
3.	Specified Make or brand of Poly carbonate sheet - Kindly confirm the make / brand of clear polycarbonate sheet for item no. 1.5 (Sr. No. 6)	Poly carbonate sheet should be as per ASTM standards and of good quality.
4.	Brand of ACM Sheet - Kindly confirm the brand or make of Aluminum composite material for item no. 1.6(Sr. no. 7).	Aluminum Composite Panel should be ISO certified and of good quality
5.	Nonlit or Backlit – Please elaborate the item no. 1.1 that boards are nonlit or backlit.	Boards will be Non-Lit.
6.	Scope of Foundation – Please confirm in item no. 1.2 that foundation is in DMRC's scope or in the scope of bidder.	Foundation will in bidder's Scope of Work.
7.	Pasting of Vinyl Graphics – Please clarify that vinyl graphics to be paste on SS plate or not in item no. 1.7.	Vinyl graphics will not be pasted on SS plate, however etching will required to be done of SS plate as per specifications mentioned in Item Code 1.7
8.	Vinyl graphics – Please mention the clear term in item no. 1.8 about vinyl graphics pasting on aluminum clipon frame.	Vinyl graphics will not be pasted on Aluminum Clip on frame.